

GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No. : WBFES/ 6088/14 /24Pgs-(N)RB/900/14 (900/14) Date : 08.12.17

From : The Director in Charge (Fire Prevention Wing)  
West Bengal Fire & Emergency Services.

To : The Authorised Signatory,  
Riya Green Valley LLP,  
Seuli Gram Panchayat, Mouza-Telinipara,  
P.S.-Titagarh, Dist.-24Pgs (N).




Sub : Waive of 100 mm dia Wet Riser, instead 150 mm dia Ringmain Hydrant system to be installed for proposed construction of 7 Blocks of G+IV Storied Residential Building at premises No.- R.S. Gad No-4964, 4965, 4969, 4961, 4960, 4970, 4957, Khatian No-5538 to 5558, seuli Gram Panchayat, Mouza-Telinipara, P.S.-Titagarh, Dist.-24Pgs(N).

Ref: Memo no WBFES/3164/14/24Pgs (N)-RB/900/14(900/14)dt.13-08-14.

In reference to the above noted subject & after carefully scrutinized plan drawings and the area of the buildings of the housing complex and as per NBC Part-V this department considered and waived the following recommendation as prayed for.

- 1) 100 mm dia Wet Riser is hereby waived.
- 2) Instead of 100mm dia wet riser, installation of Ring main Hydrant System of 150 mm internal dia is hereby considered.
- 3) All other recommendations issued earlier stated in the reference shall be remain same and strictly to be followed.

  
Director in Charge  
Fire Prevention Wing

WEST BENGAL FIRE & EMERGENCY SERVICES



GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D, Mirza Ghalib Street, Kolkata – 700 016.

Memo No. : WBFES/3164/14

/24Pgs.(N)-RB/900/14(900/14) Date: 13/8/14

From : Director(In-Charge)  
Fire Prevention Wing  
West Bengal Fire & Emergency Services



To : Partner/ Designated Partner  
Riya Green Valley LLP  
Seuli Gram Panchayat, Mouza- Telinipara  
P.S.- Titagarh, Dist.- 24 Parganas(North)


**Subject :** Fire Safety Recommendation for proposed construction of 7 nos. Block of G+IV storied under group Residential Building at premises no. – R.S. Dag No.- 4964,4965,4969,4961,4960,4970,4957; Khatian No.- 5538 To 5558; Seuli Gram Panchayat; Mouza- Telinipara; P.S.- Titagarh; Dist.- 24 Parganas(North).

This is in reference to your letter No. – Nil dated 02.08..2014 regarding Fire Safety Recommendation for proposed construction of 7 nos. Block of G+IV storied under group Residential Building at premises no. – R.S. Dag No.- 4964,4965,4969,4961,4960,4970,4957; Khatian No.- 5538 To 5558; Seuli Gram Panchayat; Mouza- Telinipara; P.S.- Titagarh; Dist.- 24 Parganas(North).

The plan drawings submitted by you were scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this office is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Encl. :

1. One set of plan.
2. Recommendation.

  
Director(In-Charge)  
Fire Prevention Wing  
West Bengal Fire & Emergency Services