

**Government of West Bengal**  
**Office of the Director General**  
**West Bengal Fire & Emergency Services**  
**13-D, Mirza Galib Street, Kolkata-700 016**

**Memo No. :** WBFES/ 810/18

**/Kol/RB/562/11(562/11)**

**Date :** 13.02.18

**From :** Divisional Officer  
Fire Prevention Wing  
West Bengal Fire & Emergency Services

**To :** The Authorized Signatory  
Bengal Emami Housing Limited  
Emami Tower  
687, Anandapur E.M. Bypass  
2 nd. Floor  
Kolkata- 700107




**Sub:** Waiver of Fire Safety Recommendation in respect of project situated at premises no. AA-IIB/Block-6, J.L. No. 13, Mouza- Rekjoani, Rajarhat, New Town.

This is in reference to your letter dated 26.10.2017 regarding waiver prayer in respect of fire safety recommendation in respect of project consisting of 1 no. LIG Block A,B,C,D,E&F (G+IV), 1 no. MIG Block 1 (G+XI), 1 no. MIG Block 2 (G+XI), 1 no. HIG Block A1,A2,A3&A4 (G+XIII) and 1 no. HIG Block B (G+XII) under group residential buildings at premises no. AA-IIB/Block-6, J.L. No. 13, Mouza- Rekjoani, Rajarhat, New Town.

The Technical Expert Committee has gone through your prayer and opined to inform you that the prayer for installation of automatic sprinklers in all floor levels which was recommended is justified and as such to be complied with, and the prayer for waiver in respect of staircase construction having 2 hours fire rating is allowed.

Remaining all recommendations issued earlier shall remain same and strictly to be followed.



Divisional Officer  
Fire Prevention Wing  
West Bengal Fire & Emergency Services