

भारतीय विमानपत्तन प्राधिकरण
AIRPORTS AUTHORITY OF INDIA

Airport

सॉर्ट फोर्स
SPEED FORCE

AAI/ER/NOC(28/11)/ 913-915.
Date: 13.5.2011..

Bengal Emami Housing Ltd ,
EMAMI TOWER,
687,Anandapur, E.M.Bypass,
Kolkata-700107.

Sub: Issue of NOC.

1. Please refer to your letter No ERL/BEHL/AAI/2011-12/150 dated...19.5.. 2011 on the subject mentioned above..
2. This office has no objection to the construction of the proposed building by Bengal Emami Housing Ltd , here in after referred to as the applicant(s) at location Plot No-AA-IIB/BLK-6, New Town, Rajarhat, North Pgs, to height 49.46M (in figures) Forty nine decimal four six Metres(in words) Above Ground Level. So that the top of the proposed structure when erected shall not exceed ...2.55.M(Site Elevation) plus(+) 49.46M height of the structure i.e. 52.01M (Fifty two deci mel zero one metres) Above Mean Sea Level.
3. This No Objection Certificate is being issued on the express understanding that site elevation reduced level (Above Mean Sea Level)is 2.55M of the relative location of the proposed building/structure & its distances andbearings from the ARP/Runway ends as tendered by the applicant(s)are correct. If however ,at any stage it is established that the said data as tendered by the said applicant is actually different from actual data which could adversely affect aircraft operations, the structure or part(s) there of in respect of which this NOC is being issued will have to be demolished at his own cost or as may be directed by the A.A.I.. The applicant(s) is/are therefore advised in his/their own interest to verify the elevation and other data furnished for the site,before embarking on the proposed construction.

The issue of this NOC is further subject to the provisions of section 9-A of the Indian Aircraft Act 1934 and those of any notifications issued there under from time to time and under which the applicant may be called upon by the AAI to demolish in whole or in part the structure now being authorized vide this NOC.


- 5.No Radio /TV Antenna,lighting arresters,staircase,Mumtee,Overhead water tank and attachments or fixtures of any kind shall project above therestricted height indicated as in para 2.
 6. The use of oil fired or electric fired furnace is obligatory.within 8Km from the Airport
 7. This certificate is valid for a period of five years from the date of issue . If the building/structure/ chimney is not constructed & completed within the above mentioned period of five years the applicant(s) required to obtain a fresh No Objection Certificate from the Chairman, Airports Authority Of India and /or the General manager (Aerodrome)E.R. . The date of completion of building /structure/ chimney should be intimated to the Chairman/or the General Manager (Aerodrome)Eastern Region.
 8. No light or a combination of lights which by reason of its intensity, configuration or colour may cause confusion with the aeronautical ground lights of the nearby Airport shall be installed at the site at any time during or after the construction of the structure.
- * Day Marking & Night lighting with secondary power supply should be provided as per ICAO standered.
** This NOC is subject to clearance from Airport Operator,if any Defence Airfield(or one for which AAI is not the Aerodrome operator) is nearby.

Copy to:-

1)The GeneralManager(NOC), 3) Guard File
Airports Authority Of India,
Safdarjung Airport, Rajib Gandhi Bhawan,
New Delhi-110003. for information.

for AIRPORTS AUTHORITY OF INDIA

2) The Executive Engineer,
New Town Kolkata Development Authority,
3,Major Arterial Road, New Town,
Kolkata-700156


(K.K.Gupta)
General Manager(AERO)ER

(K.K.Gupta)