

GOVERNMENT OF WEST BENGAL

OFFICE OF THE DIRECTOR GENERAL

WEST BENGAL FIRE & EMERGENCY SERVICES

13D, Mirza Galib Street, Kolkata – 700016.

Memo No: WBFES/ 2543/14

Date: 18/07/14

From:

The Director (Fire Prevention)

West Bengal Fire & Emergency Services

To

The Director

Bengal GHG Nirman Pvt. Ltd.

80, Bentinck Street,

Kolkata – 700001



Sub: Consideration of your prayer regarding some points of Fire Safety Recommendation issued by this office vide Memo No. WBFES / 4873 / HOW – RB / 642 / 08 (641 / 08), dated 13.09.2013.

Sir,

This is in reference to your letter no Nil, dated 12.06.2014, in connection with consideration of your prayer regarding some points of Fire Safety Recommendation issued by this office in earlier vide Memo No. WBFES / 4873 / HOW – RB / 642 / 08 (641 / 08), Dated 13.09.2013.

However every plan drawing submitted by you was scrutinized and observed minutely from fire safety point of view and consider the following points of Fire Safety Recommendation issued by this office in earlier vide Memo No mentioned above.

1. 150 mm riser to be installed in place of 100 mm pipe line in the hydrant system.
2. Sprinkler system to be installed only in all commercial areas of ground, 1st & 2nd floor, other residential areas are not required.
3. Detection & Alarm system to be provided in all commercial areas of ground, 1st & 2nd floor, other residential floors areas are not required. But MCP will be provided in all residential floor areas.

4. As A & B block not comes under the IIC of WBFS Act 1950 with up to date amendment, so Hydrant, Sprinkler & Detection system are not required, only First Aid fire fighting extinguisher to be provided in A & B block building areas.

However, their fire safety recommendation vide memo no mentioned earlier will be unchanged & strictly followed.

Yours faithfully


DIRECTOR

(FIRE PREVENTION)

WEST BENGAL FIRE & EMERGENCY SERVICES

