

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Galib Street, Kolkata – 700 016.

Memo. No. : WBFES/ 7137/16

/ KOL-RB/1125/12(1125/12) Date: 04/11/16

From : The Director in Charge
Fire Prevention Wing
West Bengal Fire & Emergency Services

To : Mr. Harsh Sanon
Sanon Sen Associates Private Limited
5, Russel Street, Ground Floor,
Kolkata – 700 071



Sub: Revised Fire Safety Recommendation for Ground Floor and revised driveway of a proposed construction of 2 Nos.(Wing 1&8)of B+G+XIV, 2 Nos. (Wing 2&7) of B+G+XVI and 7 Nos. (Wing 3,4,5,6,9,10 & 11) of B+G+XVIII storied along with one number B+G+I storied Club House under Group Residential Building, at the premises no. 591/A, Motilal Gupta Road, Ward No. 122, Borough No. XIII, Kolkata – 700 008.

This is in reference to your letter No. nil, received on 30.06.2016 regarding Revised Fire Safety measure for Ground Floor and revised driveway of a proposed construction of 2 Nos.(Wing 1&8)of B+G+XIV, 2 Nos. (Wing 2&7) of B+G+XVI and 7 Nos. (Wing 3,4,5,6,9,10 & 11) of B+G+XVIII storied along with one number B+G+I storied Club House under Group Residential Building, at the premises no. 591/A, Motilal Gupta Road, Ward No. 122, Borough No. XIII, Kolkata – 700 008.

The revised plan drawings submitted by you were scrutinized and marked as found necessary from fire safety point of view. In returning one no. of plan with recommendation, this office is issuing **Revised Fire Safety Recommendation** in favour of the aforesaid building subject to the compliance of the recommendation issued earlier vide this office Memo. No. WBFES/6892/15/ KOL-RB/1125/12(1125/12) dated 09.09.2015 will remain unchanged and strictly to be followed. The proposal for minimum 6 M wide drive way in some places as shown with provision of greenery around driveway may be allowed with a clear open to sky space of minimum 9 M wide & 15 M long area below each Fire Refuge Area shall be maintained. The load bearing capacity of entire driveway & below each Refuge Area shall be not less than 45 M.T. However, necessary sanction and approval for such occupancy must be obtained from competent authorities.

Encl. :

1. One no. of plan.


DIRECTOR IN CHARGE

FIRE PREVENTION WING

WEST BENGAL FIRE & EMERGENCY SERVICES