

**FORM 4**

[See Rules 9(3) and 10(5)]

(EMBLEM OR HOLOGRAM OF THE CONCERNED AUTHORITY)

**PERMIT FOR SINKING OF NEW WELL**

[Under 7(3)(b) / 7(4)(b) / 7(5)(a) of the West Bengal Ground Water Resources (Management, Control and Regulation) Act 2005.]

**024298**2015 SLAPERMIT NO **P17280800000136501TSE**

1. (a) Name of the applicant (user) : **Shri/Smt. Everlink Builders Pvt Ltd**
  - (b) Son/Daughter of : **N/A**
  - (c) Address of the applicant : **1, Old Court house Corner, Tobacco**
  - (d) Category of farmer (Please tick) : **Small Farmer / Marginal Farmer / Others**
  - (e) Serial No. of application Form and date of submission : **69/A0059/03 dt-4-08-2014**
  - (f) Specimen signature of the user : **Rupalan**
2. Location particulars---
    - (a) District : **South 24 parganas**
    - (b) Block, Mouza, J. L. No., Plot No. : **Sonarpur, Bade Heoghy, 80, Plot-1365**
    - (c) Municipality/ Corporation : **—**
    - (d) Ward No./ Brought No., Holding No. : **—**

## 3. Particulars of the proposed well and pumping device---

- (a) Type of the well : **Tubewell**
- (b) Approx. depth of the well (m) : **250m.**
- (c) Purpose of the well : **Infrastructure**
- (d) Assembly size (for tube well) : **200 mm X 150 mm.**
- (e) Approx. strainer length (for tube well) : **30 m.**
- (f) Diameter (for dug well) : **— m.**
- (g) Type of pump to be used : **Submersible**
- (h) H.P. of the pump : **5 H.P**
- (i) Operational device : **Electric Motor**
- (j) Rate of withdrawal (m<sup>3</sup>/hr.) : **30 m<sup>3</sup>/hr.**
- (k) Maximum allowable running hours per day : **4-5 hrs/day**

This permit authorizes the owner applicant (user) to sink a well in the location specified at S.I. (2) for extraction of ground water at a rate not exceeding that as shown at S.I. (3)(j) and for running hours/day as shown at S.I. (3)(k), and is valid subject to the observance of the conditions stated overleaf.

Place : **KOLKATA**Date : **10.09.15**OFFICE  
SEALSignature of the Issuing Authority  
and Designation**GEOLOGIST, SWID**  
Sub-Div.-II E, Alipore**Conditions:**

- (1) In case of any change of ownership of the proposed well, fresh registration has to be obtained.
- (2) No change of location, design, rate of withdrawal and pumping device in respect of the proposed well as indicated at S.I. (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this permit.
- (3) In case, any of the particulars / information furnished by the applicant in his application for issuance of this permit is found to be incorrect during verification at any subsequent stage, this permit is liable for cancellation.
- (4) Any other condition imposed by the concerned Authority.

OFFICE  
SEAL

B.C.L./4/50,000/006

P.T.O



Approved in 20<sup>th</sup> SLA Dt. 10.07.15

2<sup>nd</sup> installment voucher no.40/04.09.15

Permit No: P172808000000136501TSE

Conditionality

1. 'Roof Top Rain Water' harvesting for Surface Storage (30% of the roof area can be taken up for this purpose).
2. Excavation of Pond/ Water body of size 150ft X 50ft with 2m depth is mandatory within the project area.
3. Chemical Quality Test Report from Govt./ Govt. approved Laboratory in each year to be submitted to the Geologist & Member Secretary, DLA, S-24 Pgs.
4. The Certificate of Permit will be reviewed in every year from the date of issuance of Permit-based on local hydrogeological conditions that may prevail afterwards.
5. Use of water meter conforming to ISO standards should be install at the outlet point of boring to monitor & measure the discharge & daily water consumption. The user should maintain a log book for daily water withdrawal which may be monitored by Govt. officials as assigned by DLA in a regular manner.
6. Since, Sonarpur is an Arsenic affected block, therefore, heavy withdrawal without precautionary method may cause arsenic infiltration in the deeper fresh aquifer zone. Proper sealing of the upper saline/affected layer should be done which may be monitored by Govt. officials as assigned by DLA in a regular manner.

  
Geologist

Member Secretary, DLA South 24 Parganas



**FORM 4**

[See Rules 9(3) and 10(5)]

**024239**

(EMBLEM OR HOLOGRAM OF THE CONCERNED AUTHORITY)

**PERMIT FOR SINKING OF NEW WELL****2019SLA**

[US 7(3)(b) / 7(4), (b) / 7(5)(a) of the West Bengal Ground Water Resources (Management, Control and Regulation) Act 2005.]

PERMIT NO. **P17280800000171202TSE**

1. (a) Name of the applicant (user) : **Shri/Smt. Everlink Builders Pvt Ltd**  
 (b) Son/Daughter of : **57 others**  
 (c) Address of the applicant : **N.A.**  
 (d) Category of farmer (Please tick) : **1, Old Court-House Corner, Tobacco House, 101-01 Small Farmer / Marginal Farmer / Others**

(e) Serial No. of application Form and date of submission : **89M0059;04 dl - 04.08.2014**(f) Specimen signature of the user : **Rupalan**

## 2. Location particulars---

- (a) District : **South 24 Parganas**  
 (b) Block, Mouza, J. L. No., Plot No. : **Sonarpur, Bade Hoghly, 80J712**  
 (c) Municipality / Corporation : **—**  
 Ward No. / Borough No., Holding No. : **—**

## 3. Particulars of the proposed well and pumping device---

- (a) Type of the well : **Tubewell**  
 (b) Approx. depth of the well (m) : **250m**  
 (c) Purpose of the well : **Infrastructure**  
 (d) Assembly size (for tube well) : **200 mm. X 150 mm.**  
 (e) Approx. strainer length (for tube well) : **30 m.**  
 (f) Diameter (for dug well) : **30 m.**  
 (g) Type of pump to be used : **Submersible**  
 (h) H. P. of the pump : **5 H.P.**  
 (i) Operational device : **Electric Motor**  
 (j) Rate of withdrawal (m<sup>3</sup>/hr.) : **30 m<sup>3</sup>/hr.**  
 (k) Maximum allowable running hours per day : **4-5 hrs / day**

This permit authorizes the owner applicant (user) to sink a well in the location specified at S.I.(2) for extraction of ground water at a rate not exceeding that as shown at S.I. (3) (j) and for running hours / day as shown at S.I. (3) (K), and is valid subject to the observance of the conditions stated overleaf.

Place : **Kolkata**Date : **10.07.15****OFFICE SEAL**Signature of the Issuing Authority  
and Designation.**Shindia 10.09.15****GEOLOGIST, SWID**  
Sub-Divn.-IIE, Alipore**Conditions :**

- (1) In case of any change of ownership of the proposed well, fresh registration has to be obtained.
- (2) No change of location, design, rate of withdrawal and pumping device in respect of the proposed well as indicated at S.I. (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this permit.
- (3) In case, any of the particulars / information furnished by the applicant in his application for issuance of this permit is found to be incorrect during verification at any subsequent stage, this permit is liable for cancellation.
- (4) Any other conditions imposed by the concerned Authority.

**OFFICE SEAL****P.T.O**



Approved in 20<sup>th</sup> SLA Dt. 10.07.15

2<sup>nd</sup> installment voucher no.39/04.09.15

Permit No: P17280800000171202TSE

**Conditionality**

1. 'Roof Top Rain Water' harvesting for Surface Storage (30% of the roof area can be taken up for this purpose).
2. Excavation of Pond/ Water body of size 150ft t X 50ft with 2m depth is mandatory within the project area.
3. Chemical Quality Test Report from Govt./ Govt. approved Laboratory in each year to be submitted to the Geologist & Member Secretary, DLA, S-24 Pgs.
4. The Certificate of Permit will be reviewed in every year from the date of issuance of Permit-based on local hydrogeological conditions that may prevail afterwards.
5. Use of water meter conforming to ISO standards should be install at the outlet point of boring to monitor & measure the discharge & daily water consumption. The user should maintain a log book for daily water withdrawal which may be monitored by Govt. officials as assigned by DLA in a regular manner.
6. Since, Sonarpur is an Arsenic affected block, therefore, heavy withdrawal without precautionery method may cause arsenic infiltration in the deeper fresh aquifer zone. Proper sealing of the upper saline/affected layer should be done which may be monitored by Govt. officials as assigned by DLA in a regular manner.



Geologist

Member Secretary, DLA South 24 Parganas

16.09.15