

GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIRECTOR GENERAL
WEST BENGAL FIRE & EMERGENCY SERVICES
13-D, Mirza Ghalib Street, Kolkata – 700 016.

Memo. No. : WBFES/6667 / 17 / Kol-RB /668/14/ (668/14)

Date: 28.08.17

From : Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services.

To : The Director,
Swastik Projects Pvt. Ltd.,
12, Shakespeare Sarani,
Kolkata – 700 071.



Sub : Revised Fire Safety Recommendation for Proposed Construction of G+X Instead of G+IX Storied Under Group Residential Building at the Premises No.- 75, Pandit Madan Mohan Malavya Sarani, Ward No.-69, Borough No.-VIII, Kolkata – 700 020.

This is in reference to your Letter No.- Nil, Dated.- 14.07.2017, Regarding Revised Fire Safety Recommendation for Proposed Construction of G+X Instead of G+IX Storied Under Group Residential Building at the Premises No.- 75, Pandit Madan Mohan Malavya Sarani, Ward No.-69, Borough No.-VIII, Kolkata – 700 020.

The revised plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan, this office has approved **Revised Plan Drawing** in favour of the aforesaid building subject to the compliance of the Fire Safety Measure and **the automatic Sprinkler installation shall be provided in first floor community hall & pantry area of the building as per I.S. 9972** and as Recommendation issued earlier vide this office memo no. WBFES/1600/14/ Kol-RB /668/14/ (668/14) Dated-10/06/14 remains same & shall strictly to be followed. However, necessary sanction and approval for such construction and occupancy must be obtained from competent authorities.

Enclose:

1. One set of plan.


Divisional Fire Officer
Fire Prevention Wing
West Bengal Fire & Emergency Services