

**GOVERNMENT OF WEST BENGAL  
OFFICE OF THE DIRECTOR GENERAL  
WEST BENGAL FIRE & EMERGENCY SERVICES  
13-D Mirza Ghalib Street, Kolkata- 700 016**

Memo No : IND/WB/FES/20172018/2028

DATE: 24/01/2018

**From :**

**The Director**

**Fire Prevention Wing,**

**West Bengal Fire & Emergency Services.**

**To :**

**GAURANG MEHTA AS CONSTITUTED ATTORNEY OF BANANI SARMA APARAJITA  
SARMA AND JAYDEEP SARMA**

**4 J.K.PAUL ROAD KMC WARD NO 119 BOROUGH XIII KOLKATA 700038**

**Tollygunge F.S., New Alipore,**

**Kolkata - 700038 .**

**Sub : Fire Safety Recommendation for null construction of: G + 11 storied building  
under group Residential at the Premises No.- 4 J.K.PAUL ROAD KMC WARD NO 119  
BOROUGH XIII KOLKATA 700038**

This is in reference to your Application No. IND/WB/FES/20172018/2028, dated 24/01/2018, regarding the Fire Safety Measure for null construction of G + 11 storied building under group Residential at the premises no.- 4 J.K.PAUL ROAD KMC WARD NO 119 BOROUGH XIII KOLKATA 700038, New Alipore, Kolkata - 700038.

The plan submitted by you was scrutinized and marked as found necessary from Fire Safety point of view. In returning one set of plan with recommendation, this is issuing Fire Safety Recommendation in favour of the aforesaid building subject to the compliance of the following fire safety measure.

Recommendation:

1. C.STAIRCASE:

1.The staircase of the building shall be enclosed type. Entire construction shall be made of