

FORM 4

[See Rules 9(3) and 10(5)]

(EMBLEM OR HOLOGRAM OF THE CONCERNED AUTHORITY)

PERMIT FOR SINKING OF NEW WELL

[U/S 7(3)(b) / 7(4)(b) / 7(5)(a) of the West Bengal Ground Water Resources (Management, Control and Regulation) Act 2005.]

PERMIT NO P17 28 008 0043300811 0175E

024300

1. (a) Name of the applicant (user)
- (b) Son / Daughter of
- (c) Address of the applicant
- (d) Category of farmer (Please tick)
(in case of irrigation well)
- (e) Serial No. of application Form
and date of submission
- (f) Specimen signature of the user



: Shri/Smt. Devaloke Developers Pvt Ltd
: N.A.
: 47, Glavia Main Road, Kolkata - 700047
: Small Farmer / Marginal Farmer / Others

: BP/A 00 59, 58, dt - 8.04.2011

: Devaloke Developers Ltd.

2. Location particulars---

- (a) District
- (b) Block, Mouza, J. L. No., Plot No.
- (c) Municipality / Corporation
Ward No. / Borough No., Holding No.

: South 24 parganas
: Sonarpur, Jaganna Hipur, 51
: PLt - 433/811
: 117, Ward NO-8, Rajpur-Sonarpur Municipality

3. Particulars of the proposed well and pumping device---

- (a) Type of the well
- (b) Approx. depth of the well (m)
- (c) Purpose of the well
- (d) Assembly size (for tube well)
- (e) Approx. strainer length (for tube well)
- (f) Diameter (for dug well)
- (g) Type of pump to be used
- (h) H. P. of the pump
- (i) Operational device
- (j) Rate of withdrawal (m³/hr.)
- (k) Maximum allowable running hours per day

: Tube well
: 110 m.
: Infrastructure
: 200 mm. X 150 mm.
: 20 m.
: — m.
: Submersible
: 7.5 H.P.
: Electric Motor
: 25 m³/hr.
: 4-5 hrs/day

This permit authorizes the owner applicant (user) to sink a well in the location specified at S1. (2) for extraction of ground water at a rate not exceeding that as shown at S1. (3) (j) and for running hours / day as shown at S1. (3) (K), and is valid subject to the observance of the conditions stated overleaf.

Place: KOLKATA

Date: 16.09.15

OFFICE
SEAL

Signature of the Issuing Authority
and Designation.

Conditions:

- (1) In case of any change of ownership of the proposed well, fresh registration has to be obtained.
- (2) No change of location, design, rate of withdrawal and pumping device in respect of the proposed well as indicated at S1. (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this permit.
- (3) In case, any of the particulars / information furnished by the applicant in his application for issuance of this permit is found to be incorrect during verification at any subsequent stage, this permit is liable for cancellation.
- (4) Any other condition imposed by the concerned Authority.

GEOLOGIST, SWID

South 24-Parganas

OFFICE
SEAL


Approved in 20th SLA Dt. 10.07.15

2ND Installment Voucher No.121 dt.09.09.15

Permit No: P 17 28 0080043300811 01TSE

Conditionality

1. 'Roof Top Rain Water' harvesting for Surface Storage (30% of the roof area can be taken up for this purpose).
2. Excavation of Pond/ Water body of size 150ft X 50ft with 2m depth is mandatory within the project area.
3. Chemical Quality Test Report from Govt./ Govt. approved Laboratory in each year to be submitted to the Geologist & Member Secretary, DLA, S-24 Pgs.
4. The Certificate of Permit will be reviewed in every year from the date of issuance of Permit-based on local hydrogeological conditions that may prevail afterwards.
5. Use of water meter conforming to ISO standards should be install at the outlet point of boring to monitor & measure the discharge & daily water consumption. The user should maintain a log book for daily water withdrawal which may be monitored by Govt. officials as assigned by DLA in a regular manner.
6. Since, Sonarpur is an Arsenic affected block, therefore, heavy withdrawal without precautionary method may cause arsenic infiltration in the deeper fresh aquifer zone. Proper sealing of the upper saline/affected layer should be done which may be monitored by Govt. officials as assigned by DLA in a regular manner.


16.09.15

Geologist

Member Secretary, DLA South 24 Parganas

FORM 4

[See Rules 9(3) and 10(5)]

024301

(EMBLEM OR HOLOGRAM OF THE CONCERNED AUTHORITY)

PERMIT FOR SINKING OF NEW WELL

[U/S 7(3)(b) / 7(4)(b) / 7(5)(a) of the West Bengal Ground Water Resources
(Management, Control and Regulation) Act 2005.]PERMIT NO. P4728008000000046002TSE

1. (a) Name of the applicant (user)
- (b) Son / Daughter of
- (c) Address of the applicant
- (d) Category of farmer (Please tick)
(in case of irrigation well)
- (e) Serial No. of application Form
and date of submission
- (f) Specimen signature of the user



: Shri/Smt. Develoke Developers
 : N.A.
 : 47, Garia Main Road, KOL-70004
 : Small Farmer / Marginal Farmer / Others

2. Location particulars---

- (a) District
- (b) Block, Mouza, J. L. No., Plot No.
- (c) Municipality / Corporation
Ward No. / Borough No., Holding No.

: BPTA 0059, 59 dt - 08.04.2015
 : Develoke Developers Ltd.
South 24 Parganas
Sonarpur, Jagannathpur, 51, 46
117 - 8 - Rajpursonar Municipa

3. Particulars of the proposed well and pumping device---

- (a) Type of the well
- (b) Approx. depth of the well (m)
- (c) Purpose of the well
- (d) Assembly size (for tube well)
- (e) Approx. strainer length (for tube well)
- (f) Diameter (for dug well)
- (g) Type of pump to be used
- (h) H. P. of the pump
- (i) Operational device
- (j) Rate of withdrawal (m³/hr.)
- (k) Maximum allowable running hours per day

: Tubewell
 : 110m
 : Infrastructure
 : 200 mm. X 150 mm.
 : 20 m.
 : — m.
 : Submersible
 : 7.5 H.P.
 : Electric Motor
 : 25 m³/hr.
 : 4-5 hrs/day

This permit authorizes the owner applicant (user) to sink a well in the location specified at S1. (2) for extraction of ground water at a rate not exceeding that as shown at S1. (3) (j) and for running hours / day as shown at S1. (3) (K), and is valid subject to the observance of the conditions stated overleaf.

Place : KOLKATADate : 16.09.15OFFICE
SEALSignature of the Issuing Authority
and Designation.

Conditions :

- (1) In case of any change of ownership of the proposed well, fresh registration has to be obtained.
- (2) No change of location, design, rate of withdrawal and pumping device in respect of the proposed well as indicated at S1. (2) and (3) of this certificate shall be made without prior permission of the Competent Authority. Any deviation in this regard shall lead to cancellation of this permit.
- (3) In case, any of the particulars / information furnished by the applicant in his application for issuance of this permit is found to be incorrect during verification at any subsequent stage, this permit is liable for cancellation.
- (4) Any other condition imposed by the concerned Authority.

GEOLOGIST, SWID
 Sub-Div. - II E, Alipore
 District Survey, DLA
 South 24 Parganas

OFFICE
SEAL

P-T-O


Approved in 20th SLA Dt. 10.07.15

2ND Installment Voucher No.121 dt.09.09.15

Permit No: P 17 28 0000000460 02TSE

Conditionality

1. 'Roof Top Rain Water' harvesting for Surface Storage (30% of the roof area can be taken up for this purpose).
2. Excavation of Pond/ Water body of size 150ft X 50ft with 2m depth is mandatory within the project area.
3. Chemical Quality Test Report from Govt./ Govt. approved Laboratory in each year to be submitted to the Geologist & Member Secretary, DLA, S-24 Pgs.
4. The Certificate of Permit will be reviewed in every year from the date of issuance of Permit-based on local hydrogeological conditions that may prevail afterwards.
5. Use of water meter conforming to ISO standards should be install at the outlet point of boring to monitor & measure the discharge & daily water consumption. The user should maintain a log book for daily water withdrawal which may be monitored by Govt. officials as assigned by DLA in a regular manner.
6. Since, Sonarpur is an Arsenic affected block, therefore, heavy withdrawal without precautionary method may cause arsenic infiltration in the deeper fresh aquifer zone. Proper sealing of the upper saline/affected layer should be done which may be monitored by Govt. officials as assigned by DLA in a regular manner.


Geologist

Member Secretary, DLA South 24 Parganas