

SHANTI DEVELOPERS

To,
The Secretary,
HIRA, West Bengal,
Kolkata.

13.07.2020

Sir,


The Plan of development works to be executed in the proposed project and the proposed facilities to be provided thereof including fire-fighting facilities, drinking water facilities, emergency evacuation services, use of renewable energy in our project "**ANAND VILLE – II**" AT **DAGAPUR, SILIGURI**.

Project Specifications:

- 1. Fire-Fighting:** 2,50,000 ltrs. Capacity underground water reservoir & one terrace tank of capacity min. 5,000 ltrs. to be installed at the every wing of the building complex along with suitable terrace pump, wet riser cum down comer system and Automatic sprinkler will be provided in the corridors, parking zone & means of escape & all strategic location of the building as recommended by W.B.F.E.S.
- 2. Drinking Water Facility:** Ground water to be drawn through Bore well and will be supplied through piped network after necessary treatment.
- 3. Emergency Evacuation Services:** Emergency evacuation services to be provided at central courtyard.
- 4. Use of Renewable Energy:** Use of renewable energy will be utilised as shown in Electrical D.B.R.

For Shanti Developers

SHANTI DEVELOPERS



Authorised Signatory

RANJAN