

PARTY'S COPY

Plan for Water Supply arrangement including SEMI G. & O. H. reservoirs should be submitted at the Office of the Ex-Engineer Water Supply and the sanction obtained before proceeding with the work of Water Supply any deviation may lead to disconnection.

The building materials that will be stacked on Road/Passage or Foot-path beyond 3-months or after construction of G. Floor, whichever is earlier may be seized forthwith by the K.M.C. at the cost and risk of the owner.

A suitable pump has to be provided i.e. pumping unfiltered water for the distribution to the flushing cisterns and urinals in the building incase unfiltered water from street main is not available.

CONSTRUCTION SITE SHALL BE MAINTAINED TO PREVENT MOSQUITO BREEDING AS REQUIRED US 496 (1) & (2) OF CMC ACT 1960 IN SUCH MANNER SO THAT ALL WATER COLLECTION & PARTICULARLY LIFT WELLS, VATS, BASEMENT CURING SITES, OPEN RECEPTACLES ETC. MUST BE EMPTIED COMPLETELY TWICE A WEEK.

No rain water pipe should be fixed or discharged on Road or Footpath. Drainage plan should be submitted at the Borough Executive Engineer's Office and the sanction obtained before proceeding with the drainage work.

All Building Materials to necessary & construction should conform to the standards specified in the National Building Code of India.

Necessary steps should be taken for the safety of the lives of the adjoining public and private properties during construction.

Non Commencement of Erection/ Re-Erection within Two Year will Require Fresh Application for Sanction.

DEVIATION WOULD MEAN DEMOLITION

Sanctioned subject to demolition of existing structure to provide open space as per plan before construction is started.

THE SANCTION IS VALID UP TO 17/02/2023



Approved By: MBC Meeting No. 543
Item No. 234/17-18 Dt. 19/02/2018



RESIDENTIAL BUILDING

GOVERNMENT OF WEST BENGAL
OFFICE OF THE EXECUTIVE ENGINEER
WEST BENGAL FIRE & EMERGENCY SERVICES
123, Main Road, Kolkata - 700001

Mem. No. WBS/2018/116. Kolkata-2018/116

The Member in Charge
Fire Permission Wing
West Bengal Fire & Emergency Services
123, Main Road, Kolkata-700001

M/s. ABC Construction Company Pvt. Ltd.
98, Old Post Office Road
Kolkata-700001

For Sanction of building plan for proposed construction of 1000 sq. ft. residential building at the plot no. 24, Double Street, Ward No. 101, Borough VII, Kolkata-700001.

This is referred to your letter No. 101 dated 05.11.2018 regarding Fire Safety Measure of proposed G+2D residential building. At the plot no. 24, Double Street, Ward No. 101, Borough VII, Kolkata-700001.

The plan submitted is found to be in conformity with the provisions of the Fire Safety Measures of proposed G+2D residential building. This Office is issuing this sanction subject to the conditions specified in the accompanying Fire Safety Measures.

Encl. - 1. One set of plan.
2. Recommendations.

OFFICE OF THE EX-ENGINEER (CIVIL)
BUILDING DEPARTMENT
BOROUGH-VIII
THE KOLKATA MUNICIPAL CORPORATION
104, RAJBHARATI AVENUE
KOLKATA-700029

Date: 19/02/18

The plan submitted is found to be in conformity with the provisions of the Fire Safety Measures of proposed G+2D residential building. This Office is issuing this sanction subject to the conditions specified in the accompanying Fire Safety Measures.

Encl. - 1. One set of plan.
2. Recommendations.

DIRECTOR IN CHARGE
FIRE PREVENTION WING
WEST BENGAL FIRE & EMERGENCY SERVICES