

SHREE SHYAM DEVELOPERS

KHALPARA, SILIGURI


To Date: 3rd June, 2020

The Authority
HIRA, West Bengal
Kolkata
Sir,

In the project "SWABHUMI" the plan of development works to be executed and the proposed facilities to be provided thereof are stated as below.

Project Specifications:

1. Fire-Fighting : 100000 lits. Capacity under ground water reservoir & One terrace tank of capacity min. 20,000 lits. to be installed of the building complex along with suitable terrace pump , wet riser cum down comer system and Automatic sprinkler will be provided in the corridors, parking zone & means of escape & all strategic location of the building as recommended by W.B.F.E.S..
2. Drinking Water Facility: Ground water to be drawn through Bore well and will be supplied through piped network after necessary treatment.
3. Emergency Evacuation services: Emergency evacuation services to be provided at central courtyard.
4. Use of Renewable Energy: Use of renewable energy will be utilised as shown in Electrical D.B.R.
5. And other facilities and amenities of the project which you are providing.
 - i. Community hall .

For
Shree Shyam Developer

Partner